

THE STATE CORPORATION COMMISSION OF KANSAS

Index No. 344

MIDWEST ENERGY, INC.

SCHEDULE DRIT

(Name of Issuing Utility)

Replacing Schedule Initial Sheet

Company Wide

(Territory to which schedule is applicable)

which was filed

No supplement or separate understanding shall modify the tariff as shown hereon.

Sheet 1 of 2 Sheets

7.0 Disconnection

7.1 Temporary Disconnection

a. Emergency Conditions

Company shall have the right to immediately and temporarily disconnect the facility without prior notification in cases where, in the reasonable judgment of Company, continuance of such service to Interconnecting Customer is imminently likely to (i) endanger persons or damage property or (ii) cause a material adverse effect on the integrity or security of, or damage to, Company EDS or to the electric systems of others to which the Company EDS is directly connected. Company shall notify Interconnecting Customer promptly of the emergency condition. Interconnecting Customer shall notify Company promptly when it becomes aware of an emergency condition that affects the facility that may reasonably be expected to affect the Company EDS. To the extent information is known, the notification shall describe the emergency condition, the extent of the damage or deficiency, or the expected effect on the operation of both Parties' facilities and operations, its anticipated duration and the necessary corrective action.

b. Routine Maintenance, Construction and Repair.

Company shall have the right to disconnect the facility from the Company EDS when necessary for routine maintenance, construction and repairs on the Company EDS. The Company shall provide the Interconnecting Customer with a minimum of seven (7) calendar days planned outage notification consistent with the Company's planned outage notification protocols. If the Interconnecting Customer requests disconnection by the Company at the PCC, the Interconnecting Customer will provide a minimum of seven (7) days notice to the Company. Any additional notification requirements will be specified by mutual agreement in the Interconnection Service Agreement. Company shall make an effort to schedule such curtailment or temporary disconnection with Interconnecting Customer.

c. Forced Outages.

During any forced outage, Company shall have the right to suspend interconnection service to effect immediate repairs on the Company EDS; provided, however, Company shall use reasonable efforts to provide the Interconnecting Customer with prior notice. Where circumstances do not permit such prior notice to Interconnecting

Issued _____
 Month Day Year
 Effective Upon Approval by Commission
 Month Day Year
 By *Earnest A. Lehman* President
 Earnest A. Lehman Signature of Officer Title

04-GIME-050-61E
 Approved PR
 Kansas Corporation Commission
 May 27, 2004
 /s/ Susan K. Duffy

MIDWEST ENERGY, INC.

SCHEDULE DRIT

(Name of Issuing Utility)

Replacing Schedule Initial Sheet

Company Wide

(Territory to which schedule is applicable)

which was filed _____

No supplement or separate understanding shall modify the tariff as shown hereon.

Sheet 2 of 2 Sheets

7.0 Disconnection - cont.

Customer, Company may interrupt interconnection service and disconnect the facility from the Company EDS without such notice.

d. Non-Emergency Adverse Operating Effects.

The Company may disconnect the facility if the facility is having an adverse operating effect on the Company EDS or other Customers that is not an emergency, and the Interconnecting Customer fails to correct such adverse operating effect after written notice has been provided and a maximum of forty-five (45) days to correct such adverse operating effect has elapsed.

e. Modification of the Facility

Company shall notify Interconnecting Customer if there is evidence of a material modification to the facility and shall have the right to immediately suspend interconnection service in cases where such material modification has been implemented without prior written authorization from the Company. For purposes of this section, a material modification shall be defined as any modification to the facility that changes the net output of the facility by more than ten (10) percent, or changes the available fault current from the facility by more than two (2) percent, or functionally changes the manner in which the interconnecting equipment and/or protective equipment associated with the facility operate. The Company reserves the right to make the final determination as to whether a modification constitutes a material modification.

f. Reconnection

Any curtailment, reduction or disconnection shall continue only for so long as reasonably necessary. The Interconnecting Customer and the Company shall cooperate with each other to restore the facility and the Company EDS, respectively, to their normal operating state as soon as reasonably practicable following the cessation or remedy of the event that led to the temporary disconnection.

7.2 Permanent Disconnection

The Interconnecting Customer has the right to permanently disconnect at any time with thirty (30) days written notice to the Company.

The Company may permanently disconnect the facility upon termination of the Interconnection Service Agreement in accordance with the terms thereof.

Issued _____	Month _____	Day _____	Year _____
Effective _____	Upon Approval by Commission		
	Month _____	Day _____	Year _____
By <u>Earnest A. Lehman</u>			President
Earnest A. Lehman	Signature of Officer		Title

04-GIME-090-GIE
 Approved **PR**
 Kansas Corporation Commission
 May 27, 2004
 /s/ Susan K. Duffy