

MIDWEST ENERGY, INC.

(Name of Issuing Utility)

Company Wide

(Territory to which schedule is applicable)

Replacing Schedule NMR Sheet

which was filed October 19, 2011

No supplement or separate understanding shall modify the tariff as shown hereon.

Sheet 1 of 6 Sheets

NET METERING RIDER

AVAILABILITY

Net metering service is available under this Rider at points on the Company's existing electric distribution system for Customers operating Renewable Energy Resources. Net metering service is available to Customer-generators on a first-come, first-served basis until the total rated generating capability of all interconnections under this Rider and the Renewable Parallel Generation Rider equals or exceeds five percent of the Company's peak load during the previous year. Upon reaching this limit, no additional net metering service shall be available. This Rider shall not be available for any electric service schedule allowing for resale. A net metered Customer-generator shall have the option of interconnecting renewable generation under the Company's Renewable Parallel Generation Rider. However, Customer-generators may not change between the net metering and parallel generation riders without the prior approval of the Company, and such elections shall not be for periods less than one year. Customer-generators taking service on a Time of Day (TOD) rate schedule may not take service under this Rider.

APPLICABILITY

This Rider is applicable to Customer-generators with a Company-approved interconnection agreement. This Rider is not applicable where the nameplate capability of the Customer's electrical generating system exceeds twenty-five kilowatts for residential customers or 200 kilowatts for commercial customers. Interconnected generators must be appropriately sized to Customer's electrical load.

CHARACTER OF SERVICE

Alternating current, 60 cycles, at the voltage and phase of the Company's established secondary distribution system immediately adjacent to the service location.

BILLING AND PAYMENT

The Company shall render a bill for net consumption at approximately 30-day intervals during the Company's normal billing process. Net consumption is defined as the kWh supplied by the Company to the Customer-generator minus kWh supplied by the Customer-generator and returned to the Company's grid during the billing period. Any net consumption shall be valued as follows:

Updated and Effective July 1, 2014

By  President
 Earnest Lehman Signature of Officer Title

APPROVED BY
 MIDWEST ENERGY, INC.
 BOARD OF DIRECTORS
 June 16, 2014

MIDWEST ENERGY, INC.

(Name of Issuing Utility)

Replacing Schedule NMR Sheet

Company Wide

(Territory to which schedule is applicable)

which was filed February 28, 2011

No supplement or separate understanding shall modify the tariff as shown hereon.

Sheet 2 of 6 Sheets

NET METERING RIDER

To the extent the net consumption is positive (i.e. Customer-generator took more kWh from the Company during the billing period than Customer-generator produced), the eligible Customer-generator will be billed in accordance with the Company's standard rate for Energy Charges (for the net consumption), and for any Customer Charges, Demand Charges, and/or any Minimum Charges that would otherwise be applicable to the Customer under the standard rate.

To the extent the net consumption is negative (i.e. Customer-generator produced more kWh during the billing period than the Company supplied), the Customer-generator will pay applicable Customer Charges, Demand Charges, or both, depending upon the Company's standard rate applicable to the Customer; and the excess electric energy shall be retained by the Company as a contribution to fixed costs associated with owning and maintaining the facilities required to provide electric service when the interconnected generator cannot meet Customer's supply needs.

To the extent the net consumption is zero (i.e. the Customer-generator produced the same kWh during the billing period as was supplied by the Company), the Customer generator will be billed in accordance with the Company's otherwise applicable standard rate for the eligible Customer-generator, including any applicable Customer Charges, Demand Charges and/or Minimum Charges.

APPROPRIATE SIZE

Company may refuse interconnection of any generating facility with a rated generating capacity greater than Customer's annual peak electric load.


DEFINITIONS

Customer-generator:

The owner or operator of a qualified electric energy generation unit which:

- (a) Is powered by a Renewable Energy Resource as defined by Kansas state statutes (see definition below);
- (b) Is located on a premises owned, operated, leased, or otherwise controlled by the Customer-generator;
- (c) Is interconnected and operates in parallel phase and synchronization with the Company's system;
- (d) Meets all applicable safety, performance, interconnection, and reliability standards established by the National Electrical Code, the National Electrical Safety Code, the Institute of Electrical and Electronics Engineers, Underwriters Laboratories, the Federal Energy Regulatory Commission, and any local governing authorities; and
- (e) Contains a mechanism that automatically disables the unit and interrupts the flow of electricity back onto the Company's electric lines in the event that service to the Customer-generator is interrupted.

SAC

Issued	Month	Day	Year
Effective	Bills Rendered Or on After Novmeber 1, 2011		
By	Month	Day	Year
			President
Earnest A. Lehman			Signature of Officer
			Title

11-MDWE-609-RTS
 Approved
 Kansas Corporation Commission
 October 19, 2011
 /S/ Patrice Petersen-Klein

SCHEDULE NMR

MIDWEST ENERGY, INC.

(Name of Issuing Utility)

Replacing Schedule NMR Sheet

Company Wide

(Territory to which schedule is applicable)

which was filed February 28, 2011

No supplement or separate understanding shall modify the tariff as shown hereon.

Sheet 3 of 6 Sheets

NET METERING RIDER

Each meter connected under this Net Metering Rider defines a Customer-generator. A generator owned or operated by a Customer-generator cannot be connected in common with any other meter or be deemed to be for the purpose of serving the load connected to any other meter. To the extent that the Customer-generator controls the Renewable Energy Resources and meets the requirements and accepts all of the obligations of this Net Metering Rider, the Customer-generator is not required to own the generating facilities.

Renewable Energy Resources:

Electrical energy produced from an energy resource or technologies defined as renewable in K.S.A. 66-1257, and amendments thereto, and energy produced from municipal or other solid waste and animal waste.

Net metering:

A bi-directional metering process using equipment sufficient to measure the difference between the electrical energy supplied to a Customer-generator by Company and the electrical energy supplied by the Customer-generator to the Company over an applicable billing period.


Peak load:

The one-hour maximum annual demand imposed by the Company's retail load.

TERMS AND CONDITIONS

1. The Company will supply, own and maintain at its expense all necessary meters and associated equipment utilized for billing. In addition, and for purposes of monitoring Customer generation and load, the Company may install load research metering at its expense. The Customer shall supply, at no expense to the Company, a suitable location for meters and associated equipment used for billing and for load research. Such equipment shall be accessible at all times to utility personnel.
2. The Company shall have the right to require the Customer, at certain times and as electric operating conditions warrant, to limit the production of electrical energy from the generating facility to an amount no greater than the load at the Customer's facility of which the generating facility is a part.

SAC

Issued	Month	Day	Year
Effective	Bills Rendered Or on After Novmeber 1, 2011		
By	Month	Day	Year
 Ernest A. Lehman Signature of Officer			President Title

11-NDWE-609-RTS
 Approved
 Kansas Corporation Commission
 October 19, 2011
 /s/ Patrice Petersen-Klein

SCHEDULE NMR

MIDWEST ENERGY, INC.

(Name of Issuing Utility)

Replacing Schedule NMR Sheet

Company Wide

(Territory to which schedule is applicable)

which was filed February 28, 2011

No supplement or separate understanding shall modify the tariff as shown hereon.

Sheet 4 of 6 Sheets

NET METERING RIDER

3. The Customer shall furnish, install, operate and maintain in good order and repair without cost to the Company such relays, locks and seals, breakers, automatic synchronizers, disconnecting devices, and other control and protective devices as shall be designated by the Company as being required as suitable for the operation of the generator in parallel with the Company's system.
4. The Customer shall install and maintain a visible, manual disconnect switch. This manual switch must have the capability to be locked out by Company personnel to isolate the Company's facilities in the event of an electrical outage on the Company's transmission and distribution facilities serving the Customer. This isolating device shall also serve as a means of isolation for the Customer's equipment during any Customer maintenance activities, routine outages or emergencies. The Company shall give notice to the Customer before a manual switch is locked or an isolating device used, if possible; and otherwise shall give notice as soon as practicable after locking or isolating the Customer's facilities.
5. The Customer shall reimburse the Company for any equipment, facilities, protective equipment or upgrades required solely as a result of the installation by the Customer of generation in parallel with the Company's system.
6. The Customer shall notify the Company prior to the initial energizing and start-up testing of the Customer-owned generator, and the Company shall have the right to have a representative present at said test.
7. If harmonics, voltage fluctuations, or other disruptive problems on the Company's system are directly attributable to the operation of the Customer's system, such problem(s) shall be corrected at the Customer's expense.
8. No Customer's generating system shall damage the Company's system or equipment or present an undue hazard to Company personnel. The Company shall not be liable directly or indirectly for permitting or continuing to allow an attachment of a net metered facility or for the acts or omissions of a Customer-generator that cause loss or injury, including death, to any third party. The Customer-generator agrees to hold the Company harmless from injury or property damage incurred by any person and arising out of the ownership, operation, maintenance, or use of the Customer's electrical generation facility and to indemnify the Company against all liability and expense related thereto.

SAC

Issued _____
 Month Day Year
 Effective Bills Rendered Or on After Novmeber 1, 2011
 Month Day Year
 By Earnst A. Lehman President
 Earnest A. Lehman Signature of Officer Title

11-MDWE-609-RTS
 Approved
 Kansas Corporation Commission
 October 19, 2011
 /s/ Patrice Petersen-Klein

MIDWEST ENERGY, INC.
(Name of Issuing Utility)

Replacing Schedule NMR Sheet

Company Wide
(Territory to which schedule is applicable)

which was filed February 28, 2011


No supplement or separate understanding shall modify the tariff as shown hereon.

Sheet 5 of 6 Sheets

NET METERING RIDER

9. Prior to installing and interconnecting a Renewable Energy Resource the Customer shall enter into a standard interconnection contract with the Company setting forth the conditions related to technical and safety aspects of parallel generation.
10. Service under this Net Metering Rider is subject to the Company's approved Distributed Resource Interconnection Tariff and Terms and Conditions and subsequent modifications thereto.
11. The Customer-generator shall, at its own expense, maintain in force general liability insurance without any exclusion for liabilities related to the interconnection. The amount of such insurance shall be sufficient to insure against all reasonably foreseeable direct liabilities given the size and nature of the generating equipment being interconnected, the interconnection itself and the characteristics of the system to which the interconnection is made. For Renewable Energy Resource systems having a maximum nameplate generating capability of 10 kW or less, a Customer-generator whose system meets the standards specified in Company's approved Distributed Resource Interconnection Tariff shall not be required to install additional controls, perform or pay for additional tests or distribution equipment or purchase additional liability insurance other than such general liability insurance. For Renewable Energy Resource systems having a maximum nameplate generating capability of greater than 10 kW, the Company's approved Distributed Resource Interconnection Tariff shall: (1) Set forth safety, performance and reliability standards and insurance requirements; and (2) Establish the qualifications for exemption from a requirement to install additional controls, perform or pay for additional tests or distribution equipment or purchase additional liability insurance.
12. Applications by a Customer-generator for interconnection of the qualified generation unit to the distribution system shall be accompanied by the plan for the Customer-generator's electrical generating system, including, but not limited to, a wiring diagram and specifications for the generating unit, and shall be reviewed and responded to by the Company within 30 days after receipt for systems of 10 kilowatts or less and within 90 days after receipt for all other systems. Prior to the interconnection of the qualified generation unit to the Company's system, the Customer-generator shall furnish the Company a certification from a qualified professional electrician or engineer that the installation meets the requirements of Company's approved Distributed Resource

SAC

Issued	Month	Day	Year
Effective	Bills Rendered Or on After Novmeber 1, 2011		
By	Month	Day	Year
 Earnest A. Lehman Signature of Officer			President Title

11-MDWE-609-RTS
 Approved
 Kansas Corporation Commission
 October 19, 2011
 /s/ Patrice Petersen-Klein

MIDWEST ENERGY, INC.
(Name of Issuing Utility)

Replacing Schedule NMR Sheet

Company Wide
(Territory to which schedule is applicable)

which was filed February 28, 2011

No supplement or separate understanding shall modify the tariff as shown hereon.

Sheet 6 of 6 Sheets

NET METERING RIDER

Interconnection Tariff. If the application for interconnection is approved by the Company and the Customer-generator does not complete the interconnection within one year after receipt of notice of the approval, the approval shall expire and the Customer-generator shall be responsible for filing a new application. Upon the change in ownership of a qualified Renewable Energy Resource, the new Customer-generator shall be responsible for filing a new application under this section.

SAE

Issued	Month	Day	Year
Effective	Bills Rendered Or on After Novmeber 1, 2011		
	Month	Day	Year
By	<i>Ernest A. Lehman</i>		President
	Ernest A. Lehman	Signature of Officer	Title

11-MDWE-609-RTS
Approved
Kansas Corporation Commission
October 19, 2011
/s/ Patrice Petersen-Klein